



No. 0307/ **5601**

To A.T. Con Insulation Co., Ltd.

The Department of Science Service presents the test report for the sample named “EPS Foam 1.5LB/FT” Laboratory No. L64/02298.2 as the total of 1 sample with reference to the request No. L64/02298 dated 9 March 2021.

Enclosed herewith the following result avails for your acknowledgement.

Department of Science Service

16 April 2021



Division of Engineering Materials

Tel. 0 2201 7130

Fax 0 2201 7127

E-mail: physics@dss.go.th

**TEST REPORT**

Sample's name
EPS Foam 1.5LB/FT

Mark / Brand
-

Laboratory No.
L64/02298.2

Test Result

Compressive strength, kPa 250.12

Customer's name A.T. Con Insulation Co., Ltd.

Customer's address 622/80 Bangkhunthian - Chaithale Road, Thakham, Bangkhunthian,
Bangkok 10150

Sample's description White solid

Test date 22-29 March 2021

Test method ASTM D 1621-10 (compressed to 50% of thickness)

Approved by


(Mr. Anon Pomprasit)

Scientist, Senior Professional Level

Reported by


(Mr. Kritsada Suttipan)

Scientist, Senior Professional Level

This report is only valid for the sample received. The above statement is not intended for advertising purposes and shall not be partially reproduced or manifested without the written permission from the Department of Science Service.

Department of Science Service, Ministry of Higher Education Science Research and Innovation

Rama VI Road, Ratchathewi, Bangkok 10400, Thailand

Page 2/2